



Certificate of Compliance

Certificate: 80040696

Master Contract: 270278

Project: 80165880

Date Issued: 2023-04-19

Issued To: Norgas Metering Technologies, Inc.
9840 Harwood Court,
Fairfield, Ohio, 45014
United States

Attention: Michael Dick

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: *Gavin Feng*
Gavin Feng



PRODUCTS

CLASS - C333105 - REGULATORS (GAS) Line Pressure

CLASS - C333185 - REGULATORS (GAS) Line Pressure-Certified to U.S. Standards

Line pressure regulators

| Model Number | Inlet Size | Outlet Size | Trade Name: NMT |
|-----------------------------|------------|-------------|-----------------|
| 2, 5, 10 Psi ; Class I & II | | | |
| NGR02 | 1/2" | 1/2" | |
| NGR02 | 3/4" | 3/4" | |
| NGR02 | 1" | 1" | |
| NGR02 | 1-1/4" | 1-1/4" | |



Certificate: 80040696
Project: 80165880

Master Contract: 270278
Date Issued: 2023-04-19

| | | |
|-------|--------|--------|
| NGR04 | 1-1/4" | 1-1/4" |
| NGR04 | 1-1/2" | 1-1/2" |
| NGR04 | 2" | 2" |
| NGR04 | FL 2" | FL 2" |
| NGR04 | FL 3" | FL 3" |
| | | |
| NGR06 | 1-1/4" | 1-1/4" |
| NGR06 | 1-1/2" | 1-1/2" |
| NGR06 | 2" | 2" |
| NGR06 | FL 2" | FL 2" |
| NGR06 | FL 3" | FL 3" |
| | | |
| NGR08 | 1-1/4" | 1-1/4" |
| NGR08 | 1-1/2" | 1-1/2" |
| NGR08 | 2" | 2" |
| NGR08 | FL 2" | FL 2" |
| NGR08 | FL 3" | FL 3" |

The above models are certified for operation at the following conditions/specifications:
Ambient Temperature Range: -40°C to 60°C (-40°F to 140°F)
Vent Limiter: VL-1/2, for rated pressure 2 psi only
Overpressure Protection Device: Internal Relief Valve

APPLICABLE REQUIREMENTS

CSA/ANSI Z21.80:19•CSA 6.22:19 Line Pressure Regulators

Notes:



Supplement to Certificate of Compliance

Certificate: 80040696

Master Contract: 270278

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

| Project | Date | Description |
|----------------|-------------|--|
| 80165880 | 2023-04-19 | Update report 80040696 to update the instruction manual |
| 80040696 | 2020-06-02 | Original certification of line pressure regulator models NGR02, NGR04, NGR06 and NGR08 |